

Floor	Part No.	9TH FLOOR				8TH FLOOR				7TH FLOOR	
KNX PANEL (PANEL BOARD NAME)		Side B	Side B	Side A	Side A	Side B	Side B	Side A	Side A	Side B	Side B
KNX PANEL (PANEL BOARD NAME)	Part Number	DB-B9	EDB-B9	DB-A9	EDB-A9	DB-B8	EDB-B8	DB-A8	EDB-A8	DB-B7	EDB-B7
Switch Actuator	SA/S 12.16.6.2	2	3	2	2	3	3		2	2	3
	SA/S 8.16.6.2	1						3			
	SA/S 4.16.6.2		1	1	1	1			1	1	
DALI Gateway	DG/S 2.64.1.1										
	DG/S 1.64.1.1	1	1	1	1	1	1	1	0	1	1
PRESENCE SENSOR	6131/31-24-500	56		40		52		31		58	
KEYPAD	6127/01-84-500	7		5		6		1		2	
TOUCH SCREEN	6136/07-811-500	1				1				1	
POWER SUPPLY	SU/S30.640.1	2		2		2		1		2	
BATTERY MODULE	AM/S 12.1	2		2		2		1		2	
LINE COUPLER	LK/S4.2	2		2		2		1		2	
IP ROUTER	IPR/S3.1.1	2		2		2		1		2	
BACnet GATEWAY	AC/S1.2.1	2		2		2		1		2	
FAULT MONITORING	SMB/S1.1										
AUX. POWER SUPPLY	CP-D 24/1.3	1		1		1				1	
AUX. POWER SUPPLY	CP-D 24/0.42							1			
UNIVERSAL DIMMER	UD/S 2.315.2.1					1		1		1	
UNIVERSAL DIMMER	UD/S 4.210.2.1	1									
UNIVERSAL DIMMER	UD/S 6.210.2.1					1					
BINARY INPUT	BE/S4.20.2.1	1				1				1	
	<b>TOTAL MODULES</b>	<b>107</b>	<b>56</b>	<b>95</b>	<b>44</b>	<b>121</b>	<b>52</b>	<b>69</b>	<b>40</b>	<b>101</b>	<b>52</b>
	<b>TOTAL TB</b>	<b>84</b>	<b>66</b>	<b>68</b>	<b>52</b>	<b>100</b>	<b>60</b>	<b>60</b>	<b>48</b>	<b>78</b>	<b>60</b>

Part No.	1ST FLOOR		6TH FLOOR				GROUND FLOOR				QTY	Module
	Side A	Side A	Side B	Side B	Side A	Side A	Side B	Side B	Side A	Side A		
Part Number	DB-A7	EDB-A7	DB-BT	EDB-BT	DB-AT	EDB-AT	DB-BG	EDB-BG	DB-AG	EDB-AG	Total	
SA/S 12.16.6.2	2	2	3	3	3	2	2	2	2	2	45	12
SA/S 8.16.6.2				1		1		1	1	1	9	8
SA/S 4.16.6.2	1	1	1								9	4
DG/S 2.64.1.1			2		1						2	4
DG/S 1.64.1.1	0	0	1	1		1	0	0	1	0	10	4
6131/31-24-500	36		42		53		28		32		428	0
6127/01-84-500	0		11		3				2		29	0
6136/07-811-500			1				1				5	0
SU/S30.640.1	1		2		2		1		2		17	8
AM/S 12.1	1		2		2		1		2		17	8
LK/S4.2	1		2		2		1		1		16	2
IPR/S3.1.1	1		2		2		1		1		16	2
AC/S1.2.1	1		2		1		1		1		15	4
SMB/S1.1									1		1	2
CP-D 24/1.3	1		1		1		1		1		9	3
CP-D 24/0.42											1	1
UD/S 2.315.2.1					1						2	4
UD/S 4.210.2.1											1	6
UD/S 6.210.2.1			1								2	8
BE/S4.20.2.1			1				1				5	2
<b>TOTAL MODULES</b>	<b>67</b>	<b>40</b>	<b>125</b>	<b>60</b>	<b>103</b>	<b>48</b>	<b>65</b>	<b>44</b>	<b>93</b>	<b>44</b>		
<b>TOTAL TB</b>	<b>58</b>	<b>48</b>	<b>108</b>	<b>70</b>	<b>80</b>	<b>56</b>	<b>58</b>	<b>52</b>	<b>70</b>	<b>52</b>		

Part No.	TB
Part Number	
SA/S 12.16.6.2	14
SA/S 8.16.6.2	10
SA/S 4.16.6.2	6
DG/S 2.64.1.1	6
DG/S 1.64.1.1	4
6131/31-24-500	0
6127/01-84-500	0
6136/07-811-500	0
SU/S30.640.1	2
AM/S 12.1	2
LK/S4.2	0
IPR/S3.1.1	0
AC/S1.2.1	2
SMB/S1.1	0
CP-D 24/1.3	4
CP-D 24/0.42	2
UD/S 2.315.2.1	4
UD/S 4.210.2.1	6
UD/S 6.210.2.1	8
BE/S4.20.2.1	6
<b>TOTAL MODULES</b>	
<b>TOTAL TB</b>	