

Wago Number	Description	Function	Device	Hardware Device ID	Room Location	Group Address
1	Geyser	On/Off	Ekinex 16 Channel Actuator	8B - 33/34	Kitchen	
2	Geyser	On/Off	Ekinex 16 Channel Actuator	6B - 25/26	Master Bathroom 1	
3	Geyser	On/Off	Ekinex 16 Channel Actuator	7A - 27/28	Bathroom 2	
4	Heater	On/Off	Ekinex 16 Channel Actuator	7B - 29/30	Living Room Balcony	
5	Heater	On/Off	Ekinex 16 Channel Actuator	8A - 31/32	Master Bedroom 1 Balcony	
6	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	1A -3/4	Living Room Sheer	
7	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	1B	Living Room Sheer	
8	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	2A	Living Room Blackout	
9	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	2B	Living Room Blackout	
10	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	3A	Master Bedroom Sheer	
11	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	3B	Master Bedroom Sheer	
12	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	4A	Master Bedroom Blackout	
13	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	4B	Master Bedroom Blackout	
14	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	5A	Bedroom 2 Blinds	
15	Curtain/Blind	Up/Down - Left/Right	Ekinex 16 Channel Actuator	5B	Bedroom 2 Blinds	
16	Yale Lock	Impulse - Stair Case	Ekinex 16 Channel Actuator	8B - 33/34	Foyer - For Lock - Auto Off	
17	Fan	On/Off and Speed Control	Lebenor 4 Channel Actuator	C1	Living Room Fan	
18	Fan	On/Off and Speed Control	Lebenor 4 Channel Actuator	C2	Dining Room Fan	
19	Fan	On/Off and Speed Control	Lebenor 4 Channel Actuator	C3	Master Bedroom 1 Fan	
20	Fan	On/Off and Speed Control	Lebenor 4 Channel Actuator	C4	Bedroom 2 Fan	
21	Exhaust	On/Off	Lebenor 8 Channel Actuator	C1	Kitchen	
22	Exhaust	On/Off	Lebenor 8 Channel Actuator	C2	Master Bathroom 1	
23	Exhaust	On/Off	Lebenor 8 Channel Actuator	C3	Bathroom 2	
24	Bedside Chandelier	On/Off	Lebenor 8 Channel Actuator	C4	Master Bed Room 1	
25	Bedside Chandelier	On/Off	Lebenor 8 Channel Actuator	C5	Bed Room 2	
26	Lights	On/Off	Lebenor 8 Channel Actuator	C6	Dining Room	
27	Lights	On/Off	Lebenor 8 Channel Actuator	C7	Living Room Balcony	
28	Lights	On/Off	Lebenor 8 Channel Actuator	C8	Kitchen	
29	Lights	On/Off	Meanwell 8 Channel Actuator	A	Master Bedroom 1 Balcony	
30	Lights	On/Off	Meanwell 8 Channel Actuator	B	Master Bedroom 1 Balcony	
31	Lights	On/Off	Meanwell 8 Channel Actuator	C	Bedroom 2 Balcony	
32	Lights	On/Off	Meanwell 8 Channel Actuator	D	Master Bathroom 1	
33	Lights	On/Off	Meanwell 8 Channel Actuator	E	Bathroom 2	
34	Lights	On/Off	Meanwell 8 Channel Actuator	F	Foyer	
35			Meanwell 8 Channel Actuator	G		
36			Meanwell 8 Channel Actuator	H		
37			Dali Room Power Lines	L Bottom Deck-N Middle Deck -E Top Deck	Living Room	
38			Dali Room Power Lines	L Bottom Deck-N Middle Deck -E Top Deck		
39			Dali Room Power Lines	L Bottom Deck-N Middle Deck -E Top Deck		
40			Dali Room Power Lines	L Bottom Deck-N Middle Deck -E Top Deck	Bedroom 1	
41			Dali Room Power Lines	L Bottom Deck-N Middle Deck -E Top Deck	Bedroom 2	
42			Ekinex Binary Sensor	COMMON Top Deck - NO 1 Bottom Deck	Master Bed Room 1	
43			Ekinex Binary Sensor	COMMON Top Deck - NO 2 Bottom Deck	Bedroom 2	
44			Ekinex Binary Sensor	COMMON Top Deck - NO 3 Bottom Deck	Living Room - Optional	
45			Ekinex Binary Sensor	COMMON Top Deck - NO 4 Bottom Deck	Kitchen - Optional	
46			Dali Signal	Dali +		
47			Dali Signal	Dali -		
48			Dali Signal	Dali +		
49			Dali Signal	Dali -		

Instructions

- UPS Faulty or UPS ByPass - Position Anchor Changeover MCB to DOWN Position in Automation Distribution Board.